

CERTIFICATE OF CONFORMITY

N° 4401488-4

I. APPLICANT

- Applicant : Mr Philip HIGGS
- Company name : KEE SAFETY Ltd, 1 Boulton Road, Reading, Berkshire RG2 ONH-UK

II. DESCRIPTION

- Manufacturer: KEE SAFETY Ltd
- Reference : KEEGUARD 040808-SK4
- Category of equipment: Railguard

The railguard **KEEGUARD 040808-SK4** is made of following components :

- 1 handrail of 5200 mm with reference 8-6-G
- 1 intermediate rail of 5200 mm with reference 8-6-G
- 4 stanchions with reference KGU35
- 4 foot with 1 counterweight with reference CB1P

The railguard was made up of three lengths, one central with 2200 mm and two identical with 1500 mm with 1100 mm high. It's installed against upstand.


IV. REFERENTIEL

The railguard **KEEGUARD 040808-SK4** has been tested according to article 8.2 of the standard NF EN ISO 14122-3 :2007 on a railguard with three lengths, one central with 2200 mm and two identical with 1500 mm.

V. CONCLUSION

The railguard **KEEGUARD 040808-SK4**, manufacturer KEE SAFETY Ltd, is conform to tests described on article 8.2 of the standard EN ISO 14122-3 2007 on a railguard with three lengths, one central with 2200 mm and two identical with 1500 mm. Detailed description on the testing report 4401488-001-2.

The 24th of october 2008
The Technical Manager



Guillaume QUINTIN

This certificate is included 1 page. 2 copies are delivered to the applicant

CETE APAVE SUDEUROPE

Société par Actions Simplifiée au Capital de 3 000 000 € - N° SIREN : 775 581 812 - Site Internet : www.apave.com
Locataire-gérant du fonds de commerce du CETE APAVE Lyonnaise

LYON
177 route de Sain Bel
BP 3
69811 TASSIN CEDEX

MARSEILLE
8 rue Jean-Jacques Verrazza
Z.A.C. Saumaty-Séon - BP 193
13322 MARSEILLE CEDEX 16

BORDEAUX
Z.I. avenue Gay Lussac
BP 3
33370 ARTIGUES-près-BORDEAUX